

EC CERTIFICATE

Fire Resistance of Lift Landing Doors

No: LD07-0223-0036-17

VİTAL ASANSÖR ELEKTRİK ELEKTRONİK MAKİNA SAN. LTD. ŞTİ.

FEVZI ÇAKMAK MAH. BÜSAN ÖZEL OSB ASLIM CAD. NO:35 KARATAY, KONYA, TURKEY

Product Description : Fire resistant 2 panel side opening lift landing door.

Product Type : VCK 1000 x 2010 mm (width x height)

Basis of the certificate : 2014/33/EU Lift Directive, EN 81-58:2003


CLASSIFICATION : E 120

Test Report : EFECTIS ERA AVRASYA—RFTR 17035

Conclusion : Fire resistant 2 panel side opening lift landing door meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2003, in particular for the classification indicated above.

Classification results are considered to be applicable to doors within the tolerance of $\pm$ % 30 width and + % 15 height from dimensions stated above, if all other constructional details being the same from those of type.

Selcan GÖRMÜŞ
Director



Issue Date : 23 February 2017

