

# EC CERTIFICATE

Fire Resistance of Lift Landing Doors

No: LD07-0223-0035-17

## VİTAL ASANSÖR ELEKTRİK ELEKTRONİK MAKİNA SAN. LTD. ŞTİ.

FEVZI ÇAKMAK MAH. BÜSAN ÖZEL OSB ASLIM CAD. NO:35 KARATAY, KONYA, TURKEY

**Product Description** : Fire resistant 2 panel side opening lift landing door.

**Product Type** : VTK 1000 x 2000 mm (width x height)

**Basis of the certificate** : 2014/33/EU Lift Directive, EN 81-58:2003


**CLASSIFICATION** : E 120

**Test Report** : EFECTIS ERA AVRASYA—RFTR 17034

**Conclusion** : Fire resistant 2 panel side opening lift landing door meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2003, in particular for the classification indicated above.

Classification results are considered to be applicable to doors within the tolerance of  $\pm$  % 30 width and + % 15 height from dimensions stated above, if all other constructional details being the same from those of type.

Selcan GÖRMÜŞ  
Director



**Issue Date** : 23 February 2017

